

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

ST-08-03-19-1


- Product:** Cork flooring **S 09 N**, dimension 900 mm x 200 mm x 10 mm
- Producer:** Corkart – Industria de Corticas Ltd.  
Parque Industrial de Vendas Novas, Lt 20  
7080-341 VENDAS NOVAS  
PORTUGAL
- Order:** Determination of a selected property according to EN 14041 (CE-Labeling)
- Test method:** Determination of the anti-sliding property according to EN 13893
- Test report:** 278097
- Test result:**

*The tested cork flooring can be classified regarding to the anti-sliding property according to the CE-labelling (EN 14041) as follows:*


Property	Result	Declaration according to EN 14041
Anti-sliding properties according to EN 13893	$\mu = 0,48$	class DS *

\* Requirement for class DS according to EN 14041:  $\mu \geq 0,3$

Dresden, 19.03.2008



Head of laboratory

Engineer in charge