

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

ST-08-04-01-1

**Products:** Cork glue down tiles, dimensions: 610 x 300 x 4 mm  
Cork floating floor oiled, dimensions: 900 x 300 x 10 mm  
Cork floating floor with water based varnish, dimensions: 900 x 300 x 10 mm

**Producer:** Corkart – Industria de Corticas Ltd.  
Parque Industrial de Vendas Novas, Lt 20  
7080-341 VENDAS NOVAS  
PORTUGAL

**Order:** Determination of the fire resistance according to EN ISO 9239-1


**Test report:** 276281

**Test results:**


*The tested variants of cork floorings can be evaluated for the fire resistance according to EN 14041 as follows:*

Variant	Property	Result	CE-Declaration according to EN 14041
Cork glue down tiles	Fire resistance	Fire C <sub>fl</sub> , smoke s1	Fire class C <sub>fl</sub> s1
Cork floating floor oiled		Fire C <sub>fl</sub> , smoke s1	Fire class C <sub>fl</sub> s1
Cork floating floor with water based varnish		Fire C <sub>fl</sub> , smoke s1	Fire class C <sub>fl</sub> , s1

Dresden, 01.04.2008



Head of laboratory

Engineer in charge