

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-18-11-29-03


- Product:** Floor covering – Design Concept
Product –Design cork - printing floor
Dimension – 1200 mm x 210 mm x 10,5 mm or 612 mm x440 mm x 10.5 mm
- Client:** Corkart – Industria de Corticas Ltd.
Parque Industrial de Vendas Novas, Lt 20, 7080-341 Vendas Novas, Portugal
- Order:** Testing and classification of selected properties
according to EN 14041:2008 (CE-labelling)
- Test report:** 2717544
- Test results:** *The above mentioned Cork flooring can be classified regarding to the tested properties according to EN 14041:2008 (CE-labelling) as follows:*


Properties	Results	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, Classification according to EN 13501-1:2010 - Critical heat flow - Smoke production	4.9 kW / m ² 36 % x min	Reaction to fire class C _{fi} -s1
Formaldehyde emission according to EN 717-1:2005	< LOD (96 h)	class E1

LOD = Limit of Detection

Dresden, 29/11/2018




Head of laboratory


Engineer in charge